## **HÜBNER Analog-Tachos**

LongLife<sup>®</sup> dc tachometers

## Installation and operating instructions







## **Important Notice**

- Analog-Tachos (dc tachometers) are precision speed measurement devices, which must be handled by skilled personnel with care during transportation, mounting and operation.
- The Analog-Tachos APY/ FAPY with solid shaft are driven via a torsionally stiff, flexible coupling (e.g. Hübner spring disk coupling K35) which should be slid onto the shaft with minimum axial pressure. It shaft eddy currents occur in the motor shaft, it is recommended to use an insulated coupling like the Hübner spring disk coupling K 35 with insulated hub.

**Hammering** the coupling on the shaft is not permitted because the ball bearings may be damaged.

- Shafts with a key are dynamically balanced in the factory. Therefore drives elements like couplings or pulleys must be balanced on a smooth mandrel without key.
- LongLife<sup>®</sup> dc tachogenerators are free of maintenance. The expected operating life is governed by the ball bearings, which are manufactured with a permanent lubrication. Repair or maintenance requiring dismantling should be carried out by the manufactorer.
- The devices are manufactured according to quality standard DIN ISO 9001, EU Declaration of Conformity meeting Council Directive 89/336/EEC art. 10 and annex 1 (EMC Directive).

|      |       | Carbon brushes           |                              | Ball bearings (1 set) |      |            |
|------|-------|--------------------------|------------------------------|-----------------------|------|------------|
| Туре | Pairs | Part no.                 | * <b>min. length</b><br>(mm) | DE                    | NDE  | Part no.   |
| APY  | 2     | S 7 / H 7:<br>ET.02.1057 | 5,3                          | 6002                  | 6000 | ET.05.1015 |
| FAPY | 2     |                          |                              |                       |      |            |

\* When the minimum brush length is reached, the brushes should be replaced and the commutator area should be cleaned with dry compressed air in order to ensure proper operation.

Detailed specifications of all individuell products are available.

## LongLife-DC-Tachometer







BC Adapter







Max. admissible mounting errors





Polarity for clockwise rotation of the drive, viewing mounting face

apy-fapy-us\_mb - 03A1

SIEL\_America

2744 Yorkmont Road Charlotte, NC 28208 Phone (704) 329-0200 Fax (704) 329-0217 We reserve the right to modify technical features in the interest of technological improvements